

POLICY STATEMENT #23 – HALLWAY TEMPERATURE SET POINTS

The Board of Directors of CCC No 486 is committed to realizing energy savings by ensuring that the Corporation's common element hallways are comfortably maintained within acceptable temperature levels. In this respect the Board has approved the following Hallway Temperature Set Point Policy:

During the heating season, hallways set points are to be maintained as close as possible to 20° C (68° F). During the cooling season, hallways set points are to be maintained as close to possible to 25° C (76° F).

It is understood that some fluctuation in hallway temperatures can be expected from time to time, as external sensors adjust for changing weather conditions. It is also understood that there will at times be variations in temperatures throughout the building because of air pressure differentials and warm air movement patterns. However every effort will be made to adhere to the set point policy.

Adopted by the Board of Directors on November 7, 2011